

Elektrotermo

Kall serveringsdisk ETC höj/sänk



Användningsområde

Serveringsdisken är avsedd för kallhållning av sallad etc i GN-kantiner.

Uppackning

Emballaget avlägsnas och skyddsplasten tas bort. De rostfria ytorna torkas med en fuktig trasa. Spola aldrig direkt mot värmeriets panel eller elanslutning.

Transportskador

Undersök godset noga efter uppackning och kontrollera om det utsatts för skador under transporten. Om godset är skadat ska skadan omedelbart anmälas till transportbållaget (måste anmälas inom sju dagar efter ankomst).

Transportsäkringar

Serveringsdisken är inte utrustad med några speciella transportsäkringar annat än emballaget.

Installation

Serveringsdisken är försedd med fyra ställbara fötter. Placera enheten på avsedd plats och justera in de ställbara fötterna så den står vårgrätt. Serveringsdisken ansluts till jordat uttag 230V ~.

Viktigt

Detta system innehåller flourerade växt-husgaser.

Köldmedium: R134a, GWP:1430

Köldmediamängd 0,32kg,

CO2 ekvivalenter:0,46ton

Beskrivning

Serveringsdisken är uppbyggd av en rostfri stomme. Håll med GN-anpassad bassäng. Temperaturen regleras med en elektronisk termostat.

Höjden regleras med manöverpanelen placerad på enhetens front. Höjddifferensen är 200mm (650-850mm).

Så här används serveringsdisken

Enheten bör sättas på ca 20 minuter före användning för att kylan ska komma ner i rätt temperatur. Använd kantiner av olika storlek för de olika varorna.

Allmänna råd

Enheten är klädd med laminat som kan vara känsligt mot yttre våld. Undvik att använda skarpa verktyg mot dessa ytor.

Skötsel

Serveringsdisken rengörs med skonsamt rengöringsmedel. Torka av med fuktig trasa. *Spola aldrig* direkt mot enheten. Serveringsdisken bör vara avstängt när det inte

används.

Säkerhet

Produkten är konstruerad och tillverkad enligt SS EN 60 335-2 vad gäller elsäkerheten. Hänsyn är tagen till EG's maskindirektiv beträffande hygienkraven.

Om enheten inte fungerar

Om kylanheten inte fungerar kontrollera först att säkringen är hel. Om säkringen är hel kontakta service.

Garanti

Två års garanti lämnas på produkten enligt BFS leveransbestämmelser om inte annat överenskommit. Vid garantiåtgärder måste serienummer och typbeteckning anges. Märkskylt med typbeteckning, effekt, serienummer och tillverkningsår är placerad tillsammans med elanslutningen.

Service och reservdelar

Vid behov av service kontakta er servicefirma. Reservdelar kan beställas genom Elektro Termo Storkök AB. Ta reda på beteckning och serienummer från märkskylten.

Kopplingsschema

170216-1

Tillbehör

Om ni vill beställa extra tillbehör kontakta er återförsäljare.




Tekniska data

Typ	Effekt W	Spänning V	Ström A	Strömart
ETC2	365	230	10	1~N



Reservdelsförteckning

Art.nr	Benämning
9999999	Elektronisk termostat
9999999	Huvudströmbrytare
9999999	Kylpaket 406220
2260230	Insatspropp fyrkant 30x30
2260240	Ställbar fot



4.30 DEFROST parameters

The RC31 does not perform any defrost action when inverse action is set (if act=1).

Param. code	Description	Range	Default
dPt	Defrost time period. It is the period of time between two defrost actions.	1 .. 240 (dIS)	6 h
ddt	Defrost duration. It is the duration of each defrost action. If ddt=0 the defrost function is disabled.	0 .. 240 (dIS)	30 m
dtS	Defrost time scale (ex dS). It changes the time scale of dPt and ddt. 0: dPt hours, ddt minutes. 1: dPt minutes, ddt seconds.	0 .. 1	0
dSd	Defrost start delay. It is a delay between the time to start of the defrost action and its real beginning (switch off of the output). At the power on of the controller, it starts the first defrost action after dPt hours + dSd minutes (and the successive starts after dPt). If an external contact activates the defrost action (if Eio=±4), it starts after dSd minutes.	0 .. 120 minutes	0 m
dAd	Delay to switch on the compressor after a defrost end (ex dAd). Dripping Time. After a defrost cycle, the compressor is stopped to assure dripping of possible water still present in the evaporator.	0 .. 120 minutes	0 m
ddd	Displayed during the defrost action. 0: the temperature at the defrost start; 1: the message "dEF"; 2: the SET value; 3: the currently temperature. When 0, 1, 2, the value will be shown on the display until the controller will have reached again the Set Point value.	0 .. 3	0

4.40 Various parameters

Param.	Description	Range	Default
Eio	External contact digital input operation (ex dlo). - Negative value: digital input signal is active if external contact is closed. - Positive value: dig. input is active if contact is opened. 0: disabled; ±1: not allowed; ±2: door open, switch off the main output K1 relay; ±3: S12 is the desired temperature (instead of SET); ±4: start defrost (for another defrost start command, de-activate and activate again the ext.contact); ±5: toggle to stand-by mode (the off state is not stored in memory); ±6: external alarm, switch off all the relays, switch on the optional internal buzzer and relay.	-6 .. 6	0
Eid	Ext. contact input delay (ex did). From the activation of the external contact, RC31 waits Eid minutes to start the Eio function.	0 .. 60 minutes	0 m
Prt	Probes type. 0: probe input line able to read 10Kohm NTC temperat. sensor; 1: no avail.; 2: 990ohm PTC; 3: PTC300; 4: PT1000.	0 .. 4	0
rES	Display temperature resolution. 0: the temperature is shown in tenths of degrees; 1: temperature without decimal point.	0 .. 1	0
Unt	Temperature unit measurement. 0: Celsius degree; 1: Fahrenheit degree. (changing Unt. RC31 doesn't match any parameter. Rearrange temperature param. values to adjust the control)	0 .. 1	0
oF1	Temperature probe 1 calibration. To modify the temperature value measured by the probe 1.	-10 .. 10 °C	0 °C
tdi	Temperature displayed. 0: temperature probe 1; 2: SET value; 3: the SET value is displayed and it can be adjusted simply by pressing the "Up" or "Down" keys (without enter into menu level 1). When tdi=0 or 2, pressing the "Up" key it displays for a few seconds the currently temperature measured by probe 1. When tdi=3, pressing the "Enter" key it displays for a few seconds the currently temperature measured by probe 1.	0 .. 3	0
utd	Update temperature filter. Different averages are performed to avoid noise spikes on the probe measurements. 0: filter disabled (3 measures displayed/seconds). 10: the temperature average is evaluated on the longest time span.	0 .. 10	5
LFc	Long pushing Function configuration. 0: pushing for 5s the "Function" key start/stop defrost; 1: pushing for 5s the "Function" key toggle on/off the RC31 (stand-by mode activation).	0 .. 1	0
PSS	Password setting. It is possible to set a password to access on the 2nd menu parameter. 0: password request disabled.	0 .. 999	0
LVS	Low voltage sensing. To improve the functioning, RC31 continuously verifies the power supply. 0: function disabled; 1: short voltage drop is not detected (min sensitivity); 10: short voltage drop is detected (max sensitivity).	0 .. 10	1
nAd	Slave device network address. It is the address of the controller in a bus network with ModBus-RTU protocol. 0: serial port is disabled. When a key is pushed or in programming mode, RC31 does not always answer to the serial port, (after having changed this value, the RC31 must be restarted)	0 .. 247	0

5.00 Troubleshooting

Message	Description, cause	Output
Hit	The measured temperature of probe 1 is higher than the (AHi+0.4) parameter value. If AIP=1, the temperature is higher than (SEt+AHi+0.4).	The main K1 output doesn't change. Switch on the optional buzzer or relay. *The controller starts to save the alarm data (haccp).
Lot	The measured temperature of probe 1 is lower than the (ALo+0.4) parameter value. If AIP=1, the temperature is lower than (SEt+ALo+0.4).	The main K1 output doesn't change. Switch on the optional buzzer or relay. *The controller starts to save the alarm data (haccp).
ALE	Extern alarm. When Eio=±6 and the external contact is active.	The main output K1 relay is switched off. Switch on the optional buzzer or relay.
PF1	The probe input line is opened/disconnected or short circuited. The measured temperature is out of the range.	K1, compressor (or heater) operation is according to PEr. Switch on the optional buzzer or relay.
EEP	Memory error. The parameter list could be corrupted. The fridge control is not assured. Immediately check every parameter value, save the correct value, restart the RC31.	Not predictable.
LoV	Low voltage detection on the power supply. Check the voltage value, noises (par. L20).	All the outputs are switched off.
dOP	Door opened. When Eio = ±2 and the external contact is active.	Switch off the main output K1 relay.
OFF	The controller is going to switch off the outputs and display (stand-by mode).	All the output relays are switched off.



Installation and operating instructions



RC31 II Series Electronic On/Off controllers

- KEYBOARD FUNCTIONS

Enter: to activate the programming mode and to view and to confirm the new values.

Function: 1) to show the Haccp records; 2) pushed for 5 seconds, to start or stop manually the defrost (if LFc=0) without waiting dSd, or to switch on/off the controller (if LFc=1). The off mode, or stand-by, is stored in memory; 3) in programming mode, to quit the parameters menu without saving the new values (escape command); 4) during an alarm event, to switch off the optional internal buzzer and relay.

Up: 1) to display, for a few seconds, the probe 1 snap temperature; 2) during the programming mode, to scroll the parameters menu and to increase the value of the selected parameter.

Down: 1) pushed together with the Enter key, for 5 seconds, to lock / unlock the keyboard; 2) during the programming mode, to scroll the parameters menu and to decrease the value of the selected code.

Light on → compressor is running (output relay K1 is on, Act=0);
Flashing → waiting for a time delay to switch on the compressor.

Light on → heater is running (output relay K1 is on, Act=1);
Flashing → waiting for a time delay to switch on the heater.

Light on → defrost action is running.

The upper left point is flashing in programming mode and is lit on if an external contact is active (digital input) or during the stand-by mode. The number "1" indicates the current probe temperature shown on the display.

1.00 GENERAL DESCRIPTION AND INSTALLATION NOTICE

The RC31 models are controllers specifically designed to manage static refrigerating units, for positive (or normal) temperatures. Simply modifying a parameter, it is possible to select between direct and inverse action, to control also heating appliances. The controllers have 1 analog input for ntc/pto temperature probe and 1 output relay for cooling or heating control, optionally a digital-input for an external switch and optionally 1 alarm relay or buzzer. In cooling mode, it performs defrost by stopping the compressor for a defined time. RC31 detects temperature alarm conditions referred to the temperature probe, storing into its memory the last tree events (Haccp feature). Through the TTL port, an external master device can read and write the RC31 registers, in order to monitor and change its functioning.

1.10 Installation notice

The installation must be done only by specialized personnel in accordance with the rules in force in the country where the controllers are used. The instrument is conceived for controlling and regulation, not for safety function. It must be installed in a place protected from extreme vibrations, impact, water, corrosive gases, and where temperature and moisture do not exceed the maximum rating levels indicated in the specifications. The probe is not waterproof, it should be placed with its head upward, so that drops would not penetrate into the bulb and damage the sensor. Maintain the length of the electrical wires as short as possible in order to keep the noise picked by them at low level, otherwise a shielded wire will be needed, and the shield will be connected to the ground. Pay attention to connect correctly the probe PTC300 type, it is polarized: cathode must be at ground level.

1.20 ELECTRICAL WIRING

We recommend to protect the power supply of the controller from electrical noise, spikes and especially from voltage surges and drops. This can be easily done following these recommendations:

-separate the power supply of the loads (compressor, heaters, fans) from the power supply of the controller. This alleviates problems related to voltage dips that can arise during the switch-on of the loads, that may disturb the controller's microprocessor causing unexpected resets.
-the cables of the probes and the ones of the controller supply or the loads must be separated, to reduce spikes and noise on the sensor. This improves the stability of the reading and it also makes the commutation of the device more accurate.

1.30 CRITICAL ENVIRONMENT

For applications in heavy industrial environment these rules should be followed.

- After having identified the source of noise spikes, it is recommended to apply a line filter to the source in question of the type specifically designed to solve EMC (Electromagnetic compatibility) related problems. Sometimes it may be sufficient an RC type filter, also called «snubbers», connected in parallel to the external relay coils, or circuit breakers.
- An independent power supply should be used to power the device in extreme conditions.

ATEX reserves the right to make changes without further notice to any products herein to improve reliability, function or design. ATEX does not assume any responsibility for any improper use or application of any product or circuit described herein. ATEX products are not designed, intended, or authorized to be used as components in systems or applications intended to support or sustain life, or for any other application in which the failure of the ATEX product could create a situation where personal injury or death may occur.

ATEX Industries srl

33078 S. Vito al Tagliamento – PN
Italy

Tel.: +39 0434 85183 r.a.

web: www.atex.it - e-mail: beta@atex.it



Rev.: 16-12-2014 Cod.: 82300.0102.1

2.00 TECHNICAL SPECIFICATIONS

POWER : 230 Vac $\pm$ 10% 50/60 Hz (3VA max);
SUPPLY or 115 Vac $\pm$ 10% 50/60 Hz (3VA max);
or 12 Vac/dc $\pm$ 10% (150mA max) (use only SELV power s.);
or 9..24 Vac/dc (use only SELV power supply).

INPUTS: 1 temperature sensor, 1 Digital-In external contact (max. 1mA);
types: Ntc standard 10k Ω hm@25°C Beta=3435-25/85 (-40...+125°C);
Ptc 990 Ω hm@25°C KTY81(2)-121 (meas. range -50...+150°C);
Ptc 1k Ω hm@100°C KTY84-130 (measure range -40...+300°C);
Pt1000 1k Ω hm@0°C 2-wires (measure range -50...+350°C).


OUTPUTS: 1 spst relay 250Vac 8A max resistive (K1 – main relay);
1 spst relay 250Vac 5A max resistive (optional alarm);
other main relay power are available: 16A, 2HP)

SERIAL PORT: TTL level, ModBus protocol, RTU type, 9600 baud,
8bit char, even parity, 1 bit stop;

DISPLAY: 3 digit LED, 14 mm height, high intensity red;
MEASURING RANGE: -50...+300 °C / -50 ... +572 °F (if Ptc300);
- resolution: 0,1 °C / 0,1 °F (within –19,9...+99,9);
- accuracy @25°C: $\pm$ 0,5 °C + 1 digit;
To define the max measure error, add the accuracy of the connected probe.

- connections terminal block with screw for max 2,5mm² gauge wire;
- operating temperature: –10 ... +40 °C;
- storage temperature: –25 ... +70 °C;
- storage humidity: 30 ... 90 % rH, non condensing;
- plastic casing (PC+ABS rear box, PC frontal panel);
- frontal panel IP65, if appropriate mounting gasket;
- max temperature of the switch head: 50 °C;
- pollution degree: 2;
- rated impulse voltage: 2,5 KV;
- PTF of insulating material: 175 (circuit board 250);
- class of protection against electric shock: II (for correct install.);
- class of protection against voltage sources: category II;
- type of disconnection: 1,8 micro disconnection (relay).

Typical terminal connections (See the label on top of the instrument for the right diagram connection).



3.00 SETTING THE RC31

3.10 Menu Level 1 - Adjust the main (SEt) and secondary SET POINT (desired temperature value)

- 1) Press and release the Enter key “J”. SEt is displayed. The upper point will flash to indicate programming mode entering. To view/change SI2, press “▲” or “▼” to move to SI2 (energy saving secondary Set Point);
- 2) Press and release “J” to view the Set Point value, adjust it by using “▲” or “▼” (it is only possible values inside the SLo and SHi range);
- 3) Press and release “J” to confirm the data, after 15sec, the RC31 will leave programming mode and the new data will be stored in the memory. When tdi=3, adjust the SET value simply by pressing the “Up” or “Down” keys, Then press the “Enter” key to return to the point 1).

3.20 Menu Level 2 - Adjust all the other OPERATING PARAMETERS

- 1) Press the Enter key “J” and hold it for 6 seconds. The upper point will flash to indicate programming mode entering. If no password is set (PSS=0), the code of the first variable SHy will appear, go to point 3. If password is set, will appear “PAS” request;
- 2) (password request) Press and release the Enter key “J”, “0” will be shown; press “▲” to enter the right password value and then press and release the Enter key to confirm it. If the value entered does not match the stored password (PSS), the controller exits the programming mode;
- 3) (SHy showed) press “▲” or “▼” to scroll all the parameter codes;
- 4) While a code is displayed press and release the Enter key “J” to view its content, adjust it by pressing “▲” or “▼”;
- 5) Press and release “J” to confirm the data, after 15sec, the RC31 will quit the programming mode and the data will be stored in the memory.

WARNING:

- the instrument must not be reset before leaving the programming mode, otherwise the new setting will be lost;
- if the “Function” key is pressed during the programming mode, the user will exit the progr. mode without saving. RC31 will loose the new setting;
- the controller automatically interrupts any setting operation if any push-button isn't pressed for at least 15 seconds and store the current data;
- after having modified any parameter the controller **must be restarted** (unplug and plug again) .

3.30 Keyboard locking

Press and hold both the Enter key “J” + the Down key “▼” for 6 second, in order to lock and unlock the keyboard (the upper-left point will flash). If the controller shows “PoF” it means the keyboard is locked, if it shows “PoN” the keyboard is unlocked. When the keyboard is locked it is possible to view any parameters value but not to change them.

3.40 How to show the stored alarm temperatures (Haccop feature)

The RC31 stores the last 3 temperature alarm events: the temperature of probe 1 has been lower than ALo or higher than AHl.


- when the controller is showing the temperature (i.e., not in programming mode), press and release the “Function” key;
- it will show “HcP” (Haccop) and, if any alarm data are stored, it will show “AL1”, min/max temperature reached and for how long (minutes) the temperature 1 was over ALo or AHl, then “AL2”, min/max alarm AL1 is referred to the most recent event, AL3 is the oldest.

When the RC31 is showing the Haccop data, pressing the “Function” key for 5 seconds will erase the alarm data stored (it will show “—”). The controller will show only data for alarms of events which have come back to normal. If an alarm is running, it could be ended decreasing the ALo or increasing the AHl value. At the end of an alarm the RC31 stores the Haccop data in its memory. During the defrost actions there is no alarm recording. RC31 doesn't have a battery inside, if power fails occurs it does not check/record any data. Changing the temperature measure unit (“unf” param.), the logged temperatures / parameters values reflect unit set in the past (not convert).



4.10 MAIN OUTPUT parameters

Param. code	Description	Range	Default
SEt	Set point: it is the desired temperature.	SLo .. SHi °C	5 °C
SI2	Secondary set point. Useful for the external contact function. When Eio>=3, switching an external contact, it is possible to change the active Set point value between SEt and SI2.	SLo .. SHi °C	8 °C
SHy	Set point Hysteresis (ex HYS). Delta temperature value to avoid regulating oscillations (see figures below). (i.e., if act=0, the compressor switches off at SEt and switches on at SEt+SHy value).	0..1 .. 40 °C	2 °C
SLo	Low Set Point limit (ex LoS). It is the min value of SET parameter range. The user cannot select a SEt value lower than SLo.	-50 .. SHi °C	-40 °C
SHi	High Set Point limit (ex HiS). It is the max value of SET parameter range. The user cannot select a SEt value higher than SHi.	SLo .. 285 °C	110 °C
Act	Action of the main output relay K1: direct for cooling systems, inverse for heating control. 0: direct action (refrigeration). As temperature rises over (Set+SHy), it switches on the K1 output (for a compressor); 1: inverse action (heating). As the temperature falls below (Set+SHy), RC31 switches on the K1 output (for a heater).	0 .. 1	0
rA1	Anticycle retard (ex Acy) useful for compressor drive. When the K1 output is switched-off, the controller waits at least rA1 minutes to switch on again the K1 relay. It is also the delay for the first activation of the K1 relay at power on.	0 .. 20 minutes	0 m
ro1	Retard to switch on the K1. It is the delay to switch on the K1 relay from the request to activate it. When the temperature requires to activate the K1 output, the software starts to waiting ro1 minutes before switching on the output relay. This delay is not considered when PF1. After defrost, K1 output waits also ro1 (see also dAd).	0 .. 20 minutes	0 m
PEc	Probe 1 error, output K1 mode (ex CPF). If there is a probe 1 fault (temperature out of range, shortcircuit or probe disconnected, RC31 measur.circuit fault) the RC31 starts to manage the K1 relay by time and shows PF1 on display.	0 .. 2	2
PE1	Probe 1 error, K1 relay on (ex Con). The time to switch on the K1 relay when there is a PF1 error (if PEc=2).	0 .. 45 minutes	15 m
PE0	Probe 1 error, K1 relay off (ex CoF). The time to switch off the K1 relay when there is a PF1 error (if PEc=2).	0 .. 45 minutes	30 m

Act=0 - direct action
cooling mode, K1 relay drives a compressor



Act=1 - inverse action
heating mode, K1 relay drives a heater



WARNING: during the installation, take care to set proper rA1 value to avoid compressor or relay faults.

4.20 ALARM parameters

The temperature alarm events are always linked to the probe 1. The alarm hysteresis is 0.4 °C fixed.

Param. code	Description	Range	Default
AP	Alarm type values. 0: ALo, AHl are absolute temperature values; 1: ALo, AHl are temperature values relating to the SEt value.	0 .. 1	0
ALo	Low temperature threshold alarm (ex LoA). If the temperature goes below this value (ALo<0.4), the controller activates an alarm signal on the display and starts recording the minimum temperature and the duration of the alarm (Haccop function). Also it switches on internal buzzer and alarm relay, if present (optional).	AlP=0, -50...(AHl-1) AlP=1, -50 ... -0.5 °C	-40 °C
AHl	High temperature threshold alarm (ex HiA). If the temperature goes up over this limit value (AHl>0.4), the controller activates an alarm signal on the display and starts to record the max temperature and the time duration of the alarm signal. Also it switches on internal buzzer and alarm relay, if present (optional).	AlP=0 (ALo+1)..150 AlP=1 0.5 ... 285 °C	110 °C
Adi	Alarm delay at the power on. The RC31 does not check any temperature alarm for Adi hours from the power on.	0 .. 10 hours	0 h
Al d	Alarm delay on running time. The temperature must be in the alarm range for Al d minutes to switch on the alarm signal.	0 .. 120 minutes	0 m
AdF	Alarm delay after defrost. After the end of any defrost, the RC31 waits AdF minutes before checking any temp. alarm.	0 .. 180 minutes	0 m
Ad0	Alarm delay after de-activation of the external contact (digital input). I.e., after closing the room door, the RC31 waits Ad0 minutes before checking the temperature for alarm.	0 .. 240 minutes	0 m
Ad1	Alarm delay from the activation of the external contact. The delay count starts immediately without waiting Eid. I.e., after opening the room door, the RC31 waits Ad1 minutes before checking the temperature for alarm.	0 .. 120 minutes	0 m

Note: The alarm signal management is disabled during the defrost actions (no start, nor stop alarm).
When AlP=1, ALo & AHl are always referred to the SEt value, also if SI2 is activated by an external input.